



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
DY3423	5.6	Upright	QR	3mm	1/2	Brass	155 (68)
DY3427	5.6	Pendent	QR	3mm	1/2	Brass	155 (68)
DY3429	5.6	Horizontal Sidewall	QR	3mm	1/2	Polyester	155 (68)

Prepared for:

Duyar Vana Makina San. Tic. ve A.Ş, Uğur Mumcu Mah. 2347 Sk.  
No: 7, Sultangazi, İstanbul 34265, Turkey

Manufacturing Location:

Duyar Vana Makina San. Tic. ve A.Ş, Büyükbakkalköy  
Mah.Samandira Cad.No.7 K.3, Maltepe, Turkey

FM Approvals Class: 2012, 2016, 2017

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3058106

Approval Granted: April 19, 2017

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



Member of the FM Global Group