



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
DY3327	5.6	Pendent	SR	5mm	1/2	Brass	135, 155, 175 (57, 68, 79)
DY3329	5.6	Horizontal Sidewall	SR	5mm	1/2	Polyester	135, 155, 175 (57, 68, 79)

Prepared for: Duyar Vana Makina San. Tic. ve A.Ş, Uğur Mumcu Mah. 2347 Sk.
No: 7, Sultangazi, İstanbul 34265, Turkey

Manufacturing Location: Duyar Vana Makina San. Tic. ve A.Ş, Büyükbakkalköy
Mah.Samandira Cad.No.7 K.3, Maltepe, Turkey

FM Approvals Class: 2012, 2017
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3058107

Approval Granted: November 4, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
DY3323	5.6	Upright	SR	5mm	1/2	Brass	135, 155, 175 (57, 68, 79)

Prepared for: Duyar Vana Makina San. Tic. ve A.Ş, Uğur Mumcu Mah. 2347 Sk.
No: 7, Sultangazi, İstanbul 34265, Turkey

Manufacturing Location: Duyar Vana Makina San. Tic. ve A.Ş, Büyükbakkalköy
Mah.Samandira Cad.No.7 K.3, Maltepe, Turkey

FM Approvals Class: 2016
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3058107

Approval Granted: November 4, 2016

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'David B. Fuller'.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group