



Member of the FM Global Group

CERTIFICATE OF CONFORMITY

1. FIRE PROTECTION EQUIPMENT

2. **Certificate No:** FM24US0057
3. **Equipment:** DOSY Supervisory Switch
(Type Reference and Name)
4. **Name of Listing Company:** Duyar Vana Makina Sanayi ve Ticaret Anonim Sirketi
5. **Address of Listing Company:** Osmangazi Mah 2653 Sk No.7/1,
Kirac-Esenyurt,
Istanbul, 34522, Turkiye
6. The examination and test results are recorded in confidential report number:

PR465344 dated 15 April 2024

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM 3135:2021

8. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

9. Approval Guide Listing Category:

Sprinkler System Supervision, Standard Security

Certificate issued by:

J.E. Marquedant
VP, Manager - Electrical Systems

15 April 2024

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com, www.fmaprovals.com

F 320 (Jan 23)



CERTIFICATE OF CONFORMITY

US Certificate of Conformity No: FM24US0057



Member of the FM Global Group

10. Description of Equipment:

DOSY Supervisory Switch

<i>Physical/Operating Specifications</i>	<i>DOSY</i>
Enclosure	Aluminum
Switch Contact Ratings	DOSY-1: Single Switch DOSY-2: Double Switch 10.0A @ 125/250VAC 2.5A @ 6/12/24 VDC
Operating Temperature Range	0°C to 50°C (32°F to 122°F) For indoor use only

11. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

12. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

13. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
15 April 2024	Original Issue, reference PR465344

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

F 320 (Jan 23)

