



® **TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.**
Technical and Test Institute for Construction Prague, SOE

Akreditované laboratoře, Autorizovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgány,
Inspekční orgán / Accredited Laboratories, Authorized Body, Notified Body, Technical Assessment Body, Certification Bodies,
Inspection Body • Prosecká 811/76a, Prosek, 190 00 Praha 9, Czech Republic

Notified Body 1020

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1020 – CPR – 010046993

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) and Commission Delegated Regulation (EU) No 568/2014, this certificate applies to the construction product:

Thermal insulation products for building equipment and industrial installations - Factory made flexible elastomeric foam (FEF) products

type / variation:

listed in the Annex No.1

placed on the market under the name or trade mark of

ODE YALITIM SANAYİ VE TİCARET A.Ş.

Piyale Paşa Bulvarı Ortadoğu Plaza K-12 34384 OkmeydanıŞişli / ISTANBUL/ TÜRKİYE

and produced in the manufacturing plant:

Eskişehir Organize Sanayi Bölgesi 33. Cad. No:2 Odunpazarı, Eskişehir / TÜRKİYE

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14304:2009+A1:2013

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on **27 July 2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The stamp of the Notified Body 1020

Prague, August 26, 2025



Ing. Jozef Pôbiš
Manager of the Notified Body



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditované laboratoře, Autorizovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgány, Inspekční orgán / Accredited Laboratories, Authorized Body, Notified Body, Technical Assessment Body, Certification Bodies, Inspection Body • Prosecká 811/76a, Prosek, 190 00 Praha 9, Czech Republic

Annex No.1 to the Certificate No. 1020 – CPR – 010046993

Thermal insulation products for building equipment and industrial installations - Factory made flexible elastomeric foam (FEF) products according to EN 14304:2009+A1:2013

Table No.1 – Product list

Product name	Thickness range [mm]	Reaction to fire [class]
ODE R-FLEX PRM ROLL	6 - 50	B-s3, d0
ODE R-FLEX DIAMOND ROLL	6 - 50	B-s3, d0
BE-FLEX ROLL	6 - 50	B-s3, d0
LUNAFLEX ROLL	6 - 50	B-s3, d0
ODE R-FLEX EF ROLL	6 - 50	B-s3, d0
ODE R-FLEX ST ROLL	6 - 50	B-s3, d0
ODE R-FLEX PRM PIPE	6 - 32	BL-s2, d0
ODE R-FLEX DIAMOND PIPE	6 - 32	BL-s2, d0
BE-FLEX PIPE	6 - 32	BL-s2, d0
LUNAFLEX PIPE	6 - 32	BL-s2, d0
ODE R-FLEX EF PIPE	6 - 32	BL-s2, d0
ODE R-FLEX ST PIPE	6 - 32	BL-s2, d0

The stamp of the Notified Body 1020
Prague, August 26, 2025




Ing. Jozef Pöbiš
Manager of the Notified Body